



FLOOR/ROOF
ASSEMBLY PER UL
LISTING

MIN. 4 PCF LISTED
MINERAL WOOL INSULATION
COMPRESSED PER UL
ASSEMBLY

FASTENERS AT 3" O.C.
MAX

RipTRAK Clip (RTC) ON
EACH SIDE

OUTER/OVERLAPPING
GYPSUM BOARD
STRIPS

1/2" GAP BETWEEN RipTRAK
and FRAMING STUD
FOR TOTAL DEFLECTION

1/2"

NOMINAL
JOINT

4"

1-1/2"

MIN

1-1/2"

MAX

1-1/2"

MAX

1-1/2"

MIN

1-1/2"

MAX

1-1/2"

MIN